



CFT Limited
CFT House
Mill Race Lane
Stourbridge
West Midlands
DY8 1JN

T: 01384 442277
F: 01384 442999
E: sales@cfttd.co.uk

www.cfttd.net

Our ref: JB/JG

3rd February 2019

FAO Tom Herbert
Rockwell Sheet Sales
Rockwell House
Birmingham Road
Millisons Wood
Coventry
CV5 9AZ

**NOTE - Black type batten mentioned below
adopted as standard stock batten in March 2019**

Dear Sirs,

Re: Screw Test

Please see below the details of Screw Test:-

Test Date: 1/4/19
Screws to Test: 4.9 x 25 'A' point ST/ST

Material: As Supplied – Rockwell WPC Wall Batten, Black and Brown AL-CB5025

TEST	BLACK NO PRE-DRILL	BLACK 3MM HOLE	BROWN NO HOLE	BROWN 3MM NO HOLE
1 st	3KN	5.9KN	4.5KN	4.8KN
2 nd	3.5KN	6.2KN	3.0KN	4.8KN
3 rd	3.9KN	6.5KN	3.9KN	5.2KN
4 th	3.2KN	5.9KN	2.5KN	4.9KN
5 th	3.0KN	6.2KN	3.2KN	5.4KN

Conclusion

I can see from the pull outs that the Black Type is a better material with 3mm Holes Pre-drilled.

Yours sincerely

J Brown
Business Development Executive